EXISTING DEVICES FORM

Instructions: This form must be filled out to satisfy Cross Connection Compliance Requirements. Incomplete forms will not be accepted.
List all devices used to control cross connection and list all backflow devices starting from the water meter to the last flowing tap.

Surveyor	**John Doe**	**Date**	**1/17/2017**
Facility Name and Address	**Fox Valley Roller Rink**	**Building**	
Number of Existing Devices Listed Below	**29**		

Type of Device	Quantity	Size	Manufacturer	Model	DOC Reportable DeviceSerial #	Location/Remarks
RPZ	1	3/4"	watts	919QT	56217	chemical tank- utility room
Air Gap	14	5/8"	cash acme	ASME A112.1.2		sink- bathrooms, breakroom, utility room
AntiSiphon Ball Cock	13	5/8"	cash acme	ASSE 1002		gravity toilet- bathrooms
Hose Bib	1	5/8"	cash acme	ASSE 1011		utility sink- utility room